

SURFACING (STONE BALLAST OR PAVERS ARE SUBJECT TO DESIGNER'S APPROVAL

CARLISLE ROOF GARDEN EDGE PER RG U-1.1A, RG U-1.1B & SPECS.

SURE-SEAL BALLAST RETAINING BAR FASTENED 6" (15cm) O.C.

CARLISLE HEX-HEAD FASTENERS MAXIMUM 8" (20cm) O.C.

DIMENSION VARIES

WOOD NAILER (BY OTHERS)

WATER CUT-OFF MASTIC

GUTTER (BY OTHERS)

NOTES:

1. MEMBRANE SHEET TO EXTEND 1/2" (1.5cm) MINIMUM BELOW THE METAL TERMINATION BAR.
2. COMPLY WITH ANSI/SPRI RP-14 WIND DESIGN STANDARD FOR VEGETATIVE ROOFING SYSTEMS WWW.GREENROOFS.ORG OR REFER TO CARLISLE ROOF GARDEN SPECIFICATIONS FOR RECOMMENDATIONS.
3. TERMINATE ROOT BARRIER BY EXTENDING MIN 3" (7.5cm) BEYOND ROOF GARDEN EDGE.

 CARLISLE GROWTH MEDIA  MiraDRAIN G4 DRAINAGE COMPOSITE  RB ROOT BARRIER (40-MIL NON-REINFORCED POLYPROPYLENE)  300HV PROTECTION FABRIC		 ROOF MEMBRANE  POLYSTYRENE INSULATION  SEE NOTE(S)  IRMA INSULATED ROOF MEMBRANE ASSEMBLY		MEDIUM & DEEP GUTTER EDGE - CROSS SECTION 2021 ROOF GARDEN DETAILS DETAIL NO. RG1 1.2A
--	--	---	--	---